



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010302708397

NAME AND ADDRESS OF THE APPLICANT

Katko Oy
Katko Oy, Ruosilantie 2, 00390 Helsinki, FINLAND

NAME AND ADDRESS OF THE MANUFACTURER

Katko Oy
Katko Oy, Ruosilantie 2, 00390 Helsinki, FINLAND

NAME AND LOCATION OF THE FACTORY

Katko Oy
Ruosilantie 2, 00390 Helsinki, Finland

PRODUCT NAME,MODEL AND SPECIFICATION

Load Break Switch
KU Series

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.3-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.24,2024

Valid until: Oct.23,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010302708397

Appendix : Page 1 of 2

KU

Uimp:8kV;

Ui: 800V;

Ith:

25A(KU□16),40A(KU□25),63A(KU□40),80A(KU□63),100A(KU□80),125A(KU□125);

Ue: AC400/415V, AC690V;

Ie:

KU□16:AC-21A:25A,AC-22A:16A,AC-23A:16A

KU□25:AC-21A:40A,AC-22A:25A,AC-23A:25A

KU□40:AC-21A:63A,AC-22A:40A,AC-23A:40A(400/415V),32A(690V)

KU□63:AC-21A:80A,AC-22A:63A,AC-23A:40A

KU□80:AC-21A:100A,AC-22A:80A,AC-23A:63A(400/415V),40A(690V)

KU□125:AC-21A:125A,AC-22A:125A(400/415V),80A(690V),AC-23A:63A(400/415V),40A(690V)

A(690V)

Icw: 1.7kA/1s(16A-40A), 2.0kA/1s(63A-80A), 2.3kA/1s(125A);

Icm: 2.5kA(16A-40A), 2.5kA(63A-80A),2.5kA(125A);

Usage category: AC-21A, AC-22A, AC-23A;

3P, 4P

1NO/NC, 2NO/NC;

Ith:16A;

AC-12:Ue/Ie:AC220V/16A;AC-15: Ue/Ie: AC220V/4A;

DC-12: Ue/Ie: DC220V/4A;DC-13: Ue/Ie: DC220V/0.5A

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.




CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010302708397

Appendix : Page 2 of 2



注:1 代表 AC-22A/415V 下的工作电流: 16:16A,25:25A,40:40A,63:63A,80:80A,125:125A



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.