This translated document does not have legal validity and cannot be used in isolation



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305708307

NAME AND ADDRESS OF THE APPLICANT

Katko Oy

Katko Oy, Ruosilantie 2, 00390 Helsinki, FINLAND

NAME AND ADDRESS OF THE MANUFACTURER

Katko Oy

Katko Oy, Ruosilantie 2, 00390 Helsinki, FINLAND

NAME AND LOCATION OF THE FACTORY

Katko Oy

Katko Oy, Ruosilantie 2, 00390 Helsinki, FINLAND

PRODUCT NAME, MODEL AND SPECIFICATION

Control switch

1NO40KU、1NC40KU、1NO40RT、1NC40RT、1NO40QC、1NC40QC; Ui:250V; Uimp:2.5kV; Ith: 16A; AC-15: Ue/Ie:AC250V/4A; AC-12: Ue/Ie:AC250V/16A; DC-13: Ue/Ie:DC24V/1A; IP20 (when cable assembled)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.25,2024 Valid until: Oct.24,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE: 谢肇顺



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



This translated document does not have legal validity and cannot be used in isolation



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010305708307

Appendix: Page 1 of 1

Type description:

Models: 1, followed by NO or NC, followed by 40, followed by KU or RT or QC.

NO = normally open; NC = normally closed; 40 = size of the switch the aux will be installed KU / RT / QC = type of the switch the aux will be installed

All variations: 1NO40KU;1NC40KU;1NO40RT;1NC40RT;1NO40QC; 1NC40QC All types have same electrical ratings.

This page is attached to the certificate and should be used at the same time as the certificate page.



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.